


# 無壓室專用消防散飲管 Flexible Sprinkler Hose used for clean room


# **Installation Instructions**

# EH-8000 Flexible Sprinkler Hose for Clean Room











#### Method 1

- Step 1. Tighten the Nipple(1) to the female connector prefixed on the main pipe with pipe joint compound or Teflon tape.
- Step 2. Tighten the sprinkler head to the outlet of the sprinkler hose with pipe joint compound or Teflon tape. (Torque < 5kg-m) Insert the part(7) through the top side of the pre drilled hole of the cross
  - Fix the plate(6) with the two sets T-screws to the T-frame.
- Step 3. Put the art cover to complete the installing.



### ■ Method 2

- Step 1. Tighten the Nipple(1) to the female connector prefixed on the main pipe with pipe joint compound or Teflon tape.
- Step 2. Insert the part (7) through the top side of the pre drilled hole of the cross joint carefully.
  - Fix the plate 6 with two sets T-screws to the T-frame.
- Step 3. Tighten the sprinkler head with compound or Teflon tape to the outlet 7 through the art cover.(Torque < 5kg-m)



www.ehaseflex.com

EMASE-FLEX 通力

sales@ehaseflex.com

Tel: 86-571-87176348 Fax: 86-571-87858048